



# Qualidade do ar ambiente e sistemas de ventilação energeticamente eficientes

---



21 Maio 2026



# ÍNDICE

1

Partículas

2

Qualidade do ar ambiente

3

EN 16798-3 (“Filtragem para Edifícios”)

4

Eficiência energética – UTANs

6




Recuperação de energia





# Partículas

As **PM10** e **PM2.5** são poluentes atmosféricos compostos por partículas minúsculas. As PM10 são inaláveis e ficam retidas nas vias aéreas superiores. As PM2.5 são mais perigosas: penetram profundamente nos pulmões e entram na corrente sanguínea, agravando problemas respiratórios e cardiovasculares.

## PM1 - PARTICLES: INVISIBLE AND VERY DANGEROUS!



# Ambiente Urbano vs Rural



## EN 16798-3

Norma europeia projetada para especificar a solução de filtragem correta para edifícios

CATEGORY	DESCRIPTION	TYPICAL ENVIRONMENT
ODA 1	<p><b>OUTDOOR AIR, WHICH MAY BE ONLY TEMPORARILY DUSTY</b></p> <p>Applies where the World Health Organisation WHO (2021) guidelines are fulfilled (annual mean for <math>PM_{2.5} \leq 5 \mu\text{g}/\text{m}^3</math> and <math>PM_{10} \leq 15 \mu\text{g}/\text{m}^3</math>).</p>	
ODA 2	<p><b>OUTDOOR AIR, WITH HIGH CONCENTRATIONS OF PARTICULATE MATTER</b></p> <p>Applies where PM concentrations exceed the WHO guidelines by a factor of up to 1.5 (annual mean for <math>PM_{2.5} \leq 7.5 \mu\text{g}/\text{m}^3</math> and <math>PM_{10} \leq 22.5 \mu\text{g}/\text{m}^3</math>).</p>	
ODA 3	<p><b>OUTDOOR AIR WITH VERY HIGH CONCENTRATIONS OF PARTICULATE MATTER</b></p> <p>Applies where PM concentrations exceed the WHO guidelines by a factor of greater than 1.5 (annual mean for <math>PM_{2.5} &gt; 7.5 \mu\text{g}/\text{m}^3</math> and <math>PM_{10} &gt; 22.5 \mu\text{g}/\text{m}^3</math>).</p>	

Fonte: Camfil

### Valores Típicos PM2.5

- Lisboa:  $\sim 7\text{-}10 \mu\text{g}/\text{m}^3$
- Porto:  $\sim 8\text{-}12 \mu\text{g}/\text{m}^3$
- Faro e zonas rurais:  $\sim 4\text{-}6 \mu\text{g}/\text{m}^3$
- Média nacional  $\sim 7,9 \mu\text{g}/\text{m}^3$

# EN 16798-3

Dados Portugal

## Evolução da concentração média anual de PM2,5 e do número de estações que monitorizam estas partículas




Gráfico interativo

Fonte: APA, CCDR Norte, CCDR Centro, CCDR Lisboa e Vale do Tejo, CCDR Alentejo, CCDR Algarve, DRA Açores, DRA Madeira, 2024

### média de qualidade do ar do país 2025

Quão poluído é Portugal?

AQI\*  
Índice de qualidade do ar

● 44 AQI\* US

PM2.5  
Partículas finas ( $\leq 2,5 \mu\text{m}$ )

● 7.9  $\mu\text{g}/\text{m}^3$







A concentração de PM2.5 é atualmente **1.6** vezes o valor da diretriz anual de PM2.5 da Organização Mundial da Saúde.

Fonte: [www.iqair.com/pt/portugal](http://www.iqair.com/pt/portugal)

# EN 16798-3

Classificações espaços

CATEGORY	GENERAL VENTILATION	
SUP 1		
SUP 2	<p><b>ROOMS FOR PERMANENT OCCUPATION</b> Examples: Offices, kindergardens, hotels, residential buildings, meeting rooms, exhibition halls, conference halls, theaters, cinemas and concert halls.</p>	
SUP 3	<p><b>ROOMS WITH TEMPORARY OCCUPATION</b> Examples: Shopping centers, storage, washing rooms, server rooms and copier rooms.</p>	
SUP 4	<p><b>ROOMS WITH SHORT-TERM OCCUPATION</b> Examples: Restrooms, storage rooms and stairways.</p>	
SUP 5	<p><b>ROOMS WITHOUT OCCUPATION</b> Examples: Data centers, garbage room and underground car parks.</p>	

Fonte: Camfil

# EN 16798-3

Filtragem necessária

OUTDOOR AIR			SUPPLY AIR				
			SUP 1* PM <sub>2,5</sub> ≤ 1,25 PM <sub>10</sub> ≤ 3,75	SUP 2* PM <sub>2,5</sub> ≤ 2,5 PM <sub>10</sub> ≤ 10	SUP 3** PM <sub>2,5</sub> ≤ 3,75 PM <sub>10</sub> ≤ 11,25	SUP 4 PM <sub>2,5</sub> ≤ 5 PM <sub>10</sub> ≤ 15	SUP 5 PM <sub>2,5</sub> ≤ 7,5 PM <sub>10</sub> ≤ 22,5
CATEGORY	PM <sub>2,5</sub>	PM <sub>10</sub>	ePM <sub>1</sub>	ePM <sub>1</sub>	ePM <sub>2,5</sub>	ePM <sub>10</sub>	ePM <sub>10</sub>
ODA 1	≤ 5	≤ 15	70%	50%	50%	50%	50%
ODA 2	≤ 7,5	≤ 22,5	80%	70%	70%	80%	50%
ODA 3	≤ 7,5	≤ 22,5	90%	80%	80%	90%	80%

**Table 3:** Recommended min. ePM<sub>x</sub> filtration efficiencies according to EN 16798-3 depending on ODA and SUP (annual mean PM<sub>x</sub> values in µg/m<sup>3</sup>)

\*Minimum filtration requirements ISO ePM<sub>1</sub> 50% refer to a final filter stage


\*\*Minimum filtration requirements ISO ePM<sub>2,5</sub> 50% refer to a final filter stage

# EN 779 Vs ISO 16890

EN 779-2012	ISO 16-890			
	ISO Grossier	ISO ePM10	ISO ePM2,5	ISO ePM1
G2	50-60%			
G3	50-70%			
G4	60-80%			
M5		50-70%		
M6		60-80%		
F7		80-90%	65-75%	50-65%
F8		90-100%	75-95%	65-90%
F9		90-100%	85-95%	80-90%

# Utilização de pré-filtro

Intervalos de substituição com e sem pré-filtragem



# Utilização de pré-filtro

Recomendação EUROVENT 4/23 (Referida Portaria 138º-I)

Outdoor air quality		Supply air quality				
		SUP 1	SUP 2	SUP 3	SUP 4	SUP 5
ODA 1	Example 1	ePM10 50% + ePM1 60%	ePM1 50%	ePM2,5 50%	ePM10 50%	ePM10 50%
	Example 2	ePM1 70%	-	-	-	-
ODA 2	Example 1	ePM1 50% + ePM1 60%	ePM10 50% + ePM1 60%	ePM1 50%	ePM2,5 50%	ePM10 50%
	Example 2	ePM1 80%	ePM1 70%	ePM2,5 70%	ePM10 80%	-
ODA 3	Example 1	ePM1 50% + ePM1 80%	ePM1 50% + ePM1 60%	ePM10 50% + ePM1 60%	ePM1 50%	ePM2,5 50%
	Example 2	ePM1 90%	ePM1 80%	ePM2,5 80%	ePM10 90%	ePM10 80%

Table 7: examples of filter classes meeting respective ODA/SUP categories requirements

# Eficiência filtragem “acumulada”




Figure 5: Cumulative ePM1 efficiency

Fonte: <https://www.eceuk.com/>

To facilitate rough estimations, it is recommended to use the following formula to determine the combined filtration efficiency for respective particle size fractions:

$$ePM_{x,cum} = 100 \cdot \left( 1 - \left( \left( 1 - \frac{ePM_{x,s1}}{100} \right) \cdot \left( 1 - \frac{ePM_{x,s2}}{100} \right) \cdot \dots \cdot \left( 1 - \frac{ePM_{x,sn+1}}{100} \right) \right) \right)$$

Where

$ePM_{x,cum}$  is the total cumulated efficiency for x fraction

$ePM_{x,sn+1}$  is the fractional efficiency for each filter stage

This simplified approach assumes the same particle distribution on the inlet to each of the stages. In most cases, it results in minor deviations compared to the EN ISO 16890 methodology, acceptable for engineering calculations accuracy.

However, if high accuracy is required, it is recommended to contact a filter supplier to perform relevant calculations.

Fonte: Eurovent 4/23

# Eficiência energética Filtragem

Caso prático

**Short filter section**

Air volume  m³/h

Filter:

Initial resistance  Pa

Initial resistance ERP 1253  Pa

Selection resistance  Pa

Final pressure difference  Pa

Filter surface  m²

Filter class

Filterbewertung

**Short filter section**

Air volume  m³/h

Filter:

Initial resistance  Pa

Initial resistance ERP 1253  Pa

Selection resistance  Pa

Final pressure difference  Pa


Filter surface  m²

Filter class

Filterbewertung

Filterabscheidegrade

Refer to active power(elec.)  KW



# Eficiência energética Filtragem


Caso prático

Short bag filter section	
Air volume	6000 m³/h
Filter:	Compact filter V-shape
Initial resistance	53 Pa
Initial resistance ERP 1253	60 Pa
Selection resistance	103 Pa
Final pressure difference	153 Pa
Filter surface	33,00 m²
Filter class	5
EnergieVerbrauch	900 kWh
EnergieKlasse	C
Filterbewertung	ISO ePM10 70%

Short bag filter section	
Air volume	6000 m³/h
Filter:	Compact filter V-shape
Initial resistance	60 Pa
Initial resistance ERP 1253	0 Pa
Selection resistance	110 Pa
Final pressure difference	160 Pa
Filter surface	33,00 m²
Filter class	7
EnergieVerbrauch	782 kWh
EnergieKlasse	A+
Filterbewertung	ISO ePM1 60%
Filterabscheidegrade	ePM2,5: 65% ePM10:

Refer to active power(elec.) 1,842 kW

- 0,242 kW (-12%)



# Eficiência energética Filtragem

Eurovent 21/4

M <sub>x</sub> = 400g (AC Fine)	AEC in kWh/y FOR ePM <sub>10</sub>					
	ePM <sub>10</sub> ≥ 50%					
	A+	A	B	C	D	E
50&55%	450	550	650	750	1100	>1100
60&65%	500	600	700	850	1200	>1200
70&75%	600	700	800	900	1300	>1300
80&85%	700	800	900	1000	1400	>1400
>90%	800	900	1050	1400	1500	>1500

M <sub>x</sub> = 250g (AC Fine)	AEC in kWh/y FOR ePM <sub>2,5</sub>					
	ePM <sub>2,5</sub> and ePM <sub>2,5,min</sub> ≥ 50%					
	A+	A	B	C	D	E
50&55%	700	800	950	1300	1900	>1900
60&65%	750	850	1000	1350	1950	>1950
70&75%	800	900	1050	1400	2000	>2000
80&85%	900	1000	1200	1500	2100	>2100
>90%	1000	1100	1300	1600	2200	>2200

M <sub>x</sub> = 200g (AC Fine)	AEC in kWh/y FOR ePM <sub>1</sub>					
	ePM <sub>1</sub> and ePM <sub>1,min</sub> ≥ 50%					
	A+	A	B	C	D	E
50&55%	800	900	1050	1400	2000	>2000
60&65%	850	950	1100	1450	2050	>2050
70&75%	950	1100	1250	1550	2150	>2150
80&85%	1050	1250	1450	1800	2400	>2400
>90%	1200	1400	1550	1900	2500	>2500

$$\text{Consumption énergétique annuelle d'un filtre (kWh/an)} = \frac{Q \times \Delta P \times t}{\eta \times 1000}$$

Le débit de référence (Q) — La perte de charges moyenne (ΔP) — La durée de fonctionnement (t) — Le rendement du ventilateur (η)

# Eficiência energética Filtragem

Filtros Electroestáticos



ePM2.5 : 95%

Dim: 610x610

Caudal 3400 m/h

PdC: 17 Pa



# Eficiência energética Velocidade


Caso prático

Air velocity Energy label Eurovent	1,99 m/s	Refer to active power(elec.)	2,084 kW
Air velocity (class in accordance to EN 13053)	2,0 m/s (V3)		



Air velocity Energy label Eurovent	1,49 m/s	Refer to active power(elec.)	1,53 kW
Air velocity (class in accordance to EN 13053)	1,5 m/s (V1)		

- 0,554 kW (-27%)



# EN 13053

Norma europeia requisitos  
desempenho UTAs



Classe	Velocidade
V1	≤ 1,6 m/s
V2	1,6 – 1,8 m/s
V3	1,8 – 2,0 m/s
V4	2,0 – 2,2 m/s
V5	2,2 – 2,5 m/s
V6	2,5 – 2,8 m/s
V7	2,8 – 3,2 m/s

Classe	Eficiência de recuperação $\eta_e$ (%)
H1	≥ 71%
H2	≥ 64%
H3	≥ 55%
H4	≥ 45%
H5	≥ 36%
H6	Sem requisitos

Classe	Relação com $P_{m,ref}$
P1	≤ 0,85 × $P_{m,ref}$
P2	≤ 0,90 × $P_{m,ref}$
P3	≤ 0,95 × $P_{m,ref}$
P4	≤ 1,00 × $P_{m,ref}$
P5	≤ 1,06 × $P_{m,ref}$
P6	≤ 1,12 × $P_{m,ref}$
P7	> 1,12 × $P_{m,ref}$

$$P_{m,ref} = (\Delta P_{stat} / 450)^{0,925} \cdot (qv + 0,08)^{0,95}$$

$P_{m,ref}$  (kW) electric power consumption  
 $\Delta P_{stat}$  (Pa) Static pressure increase  
 $qv$  (m<sup>3</sup>/s) air flow



# Recuperação Energia

Roda Termica

Optimização Eficiência




Eficiência térmica do recuperador (ES 1253, 2018)

Tamanho da unidade MAX2	32	42	52	62	72
L (1.7mm)	-	76,8 %	80,1 %	82,0 %	82,8 %
ML (1.6mm)	76,9 %	81,1 %	83,4 %	84,3 %	84,4 %
SL (1.5mm)	81,5 %	84,2 %	85,7 %	86,1 %	86,0 %
Higroscópica- L	73,0 %	77,1 %	80,1 %	81,9 %	83,0 %
Higroscópica-ML	75,6 %	79,4 %	82,2 %	83,4 %	83,7 %
Higroscópica-SL	80,1 %	82,9 %	84,6 %	85,2 %	85,2 %

# Recuperação Energia

Caso pratico




6000 m<sup>3</sup>/h (insuflação e extração)

# Recuperação Energia

Caso pratico

Grupo	Parâmetro	Unidade	UTA 1	UTA 2	
<b>Velocidade</b>	Velocidade frontal	m/s	1,69	1,02	
	Classe (EN13053)	—	V2	V1	
<b>Recuperação</b>	Eficiência sensível	%	79,4	83,4	+4%
	Eficiência latente	%	76,4	88,9	
	Perda de carga recuperador	Pa	209	117	
	Classe recuperação (EN13053)	—	H1	H1	
<b>Insuflação</b>	SFPv	kW/(m <sup>3</sup> /s)	1,12	0,72	
	Potência absorvida	kW	2,07	1,3	
	Pressão estática	Pa	784	541	
<b>Extração</b>	SFPv	kW/(m <sup>3</sup> /s)	1	0,67	
	Potência absorvida	kW	1,81	1,19	
	Classe P (EN13053)	—	P1	P1	
	Pressão estática	Pa	668	495	
<b>Global</b>	▽ Potência absorvida total	kW	<b>3,88</b>	<b>2,49</b>	<b>- 36 %</b>



# Eficiência Energética

Rede de condutas





## Escritórios

### Lisboa

Avenida Casal da Serra, N.º 13, Escritório 3  
2625-085 Póvoa de Santa Iria

### Porto

Zona Industrial da Maia, Setor IX – Sul  
Rua de Eng.º João Tallone, Lote 7  
4470-516 Maia


### Algarve

Zona Industrial Vale da Venda, Lote 3, Loja A  
8005-412 Faro

## Website & Contactos

[france-air.pt](http://france-air.pt)  
[guia.france-air.pt](http://guia.france-air.pt)

[france.air.portugal@france-air.com](mailto:france.air.portugal@france-air.com)  
[orcamento@france-air.com](mailto:orcamento@france-air.com)



*Agradecemos a sua atenção.*